

Benchmarking Energy Performance: Comparative Analysis of a Laboratory Project with Operated Buildings (TRB)

Speakers:
Amy Dean, Lord Aeck Sargent
Masoom Haghani (MaHa), Lord Aeck Sargent

Oct. 21, 2025


Session G1



Comparison is the thief of JOY!

-Theodore Roosevelt

stop comparing yourself to others.





EXCEPT when Benchmarking...

Learning Objectives

1. Identify challenges in setting energy targets for laboratory buildings with complex programs and high process loads.
2. Understand the impact of campus-supplied utilities on EUI calculations and benchmarking
3. Learn how analyzing actual energy performance data from existing campus buildings can inform energy targets for new facilities.
4. Evaluate the effectiveness of industry benchmarking tools versus campus-specific data in establishing realistic energy performance goals.




THE UNIVERSITY OF NORTH CAROLINA AT CHAPEL HILL




Translational Research Building (TRB)

PROJECT
LOCATION



Translational Research Building (TRB)



Translational Research Building (TRB)



**9th
top-ranked university**

in the United States for federal research, totaling \$907M annually

\$1.55B

sponsored research from all sources annually, making it the 7th largest public US research university in research volume and annual expenditures

*2024 Data

Translational Research Building (TRB)

50%

Assigned Space



RESEARCH

Division of Comparative Medicine


50%

Assigned Space



Translational Research Building (TRB)

- Biology Labs
- Chemistry Labs
- BSL3 Facility
- Imaging Suite
- Cyclotron Suite
- Vivarium
- Cage Wash
- Offices
- Conference Rooms



WHY BENCHMARK?



EUI Introduction

Energy Use Intensity:

$$\text{EUI} = \frac{\text{Total annual energy consumption (kBtu)}}{\text{Total gross floor area (ft}^2\text{)}}$$



INITIAL DETAILED INPUT

Basic Filters

Clear

Edit

% Lab Area (Net Lab Area / Total Gross Area)

0.00 to 41.00 %

Building Status

Real Building

Type of Record

In Operation

Climate Zones

3A Warm - Humid

Data Type

Data Type

Estimated

Building Properties

Clear

Edit

Organization Type

Academic: Higher Ed

Government: State Or Local

Predominant Lab Use Types

R&D: Basic Research

Gross Floor Area (sf)

500 to 176500

Total Number of Occupants per sf

0.0000 to 0.0030

Region

North And Central America

Fume Hoods

Clear

Edit

Ducted Fume Hoods per sf of Lab Space

0.0000 to 0.0010

Filtering Fume Hoods per sf of Lab Space

0.000 to 0.000

Linear ft of Fume Hoods per sf of Lab

0.000 to 0.006

Fume Hood Operating Sash Height (inches)

6 to 18

Fume Hood Face Velocity (ft/min)

80 to 99

Predominant Fume Hood Control Type

Variable Volume

Automatic Sash Closers

Hood Face Velocity Setback

Laboratory Occupied Minimum Air Change Rate (ACH)

0.10 to 6.20

Laboratory Unoccupied Minimum Air Change Rate (ACH)

0.10 to 4.10

Source of Lab Minimum Ventilation Rates

Organizational Policy

Building Systems

Clear

Edit

Predominant HVAC System Type

Variable Volume With Reheat

Predominant HVAC Control Type

Direct Digital Control

Exhaust Air Energy Recovery

High-Performance Glycol Run-Around

Predominant Cooling System Type

District Cooling / CHW From Campus Central Plant

Predominant Heating System Type

District Heating / HW Or Steam From Campus Central Plant

Building-level CHP

None

Renewable Energy Generation at Building

None

Geothermal Heat Pump

Heat Recovery Chiller

Low Pressure Drop Design - Air Side

Low Pressure Drop Design - Water Side

True VAV Exhaust (No Bypass Air)

High-Efficiency ULT Freezers

Cascade Air Use

Water-Cooled Lab Equipment

Supply Air Temperature Reset

Static Pressure Reset - Supply Air

Static Pressure Reset - Exhaust Air

Unoccupied Airflow Setback In Labs

Unoccupied Temp Setback In Labs

Pump Head Reset

Exhaust Fan - Wind Speed Response

Chemical Sensing And Airflow Response In Labs

Energy and Operational Emissions Benchmarking

By default, all buildings are shown on the charts. Use the filters to narrow down your peer group.

Scatter Plot

loading

Select Quantities to Plot

Horizontal Axis

Lab Area

Units %

Vertical Axis *

Site EUI

Units kBtu/sf/yr

Summary Statistics for Selected Peer Group Buildings

No Matching Buildings

TRB Challenge

Laboratory

- BSL3 Suite: 9, 850 nsf
- Cyclotron Suite: 3,100 nsf
- Bio/Chem Labs: 14,250 nsf
- Total: 27,200 nsf (15%)



TRB Challenge

Vivarium


- Cagewash Suite: 5,125 nsf
- Vivarium: 40,500 nsf
- Total: 45,600 nsf (26%)



TRB Challenge

HVAC attributes

- High performance glycol run around (run around loop)



Courtesy of Affiliated Engineers

INITIAL DETAILED INPUT

Basic Filters

Clear

Edit

% Lab Area (Net Lab Area / Total Gross Area)

0.00 to 41.00 %

Building Status

Real Building

Type of Record

In Operation

Climate Zones

3A Warm - Humid

Data Type

Data Type

Estimated

Building Properties

Clear

Edit

Organization Type

Academic: Higher Ed

Government: State Or Local

Predominant Lab Use Types

R&D: Basic Research

Gross Floor Area (sf)

500 to 176500

Total Number of Occupants per sf

0.0000 to 0.0030

Region

North And Central America

Fume Hoods

Clear

Edit

Ducted Fume Hoods per sf of Lab Space

0.0000 to 0.0010

Filtering Fume Hoods per sf of Lab Space

0.000 to 0.000

Linear ft of Fume Hoods per sf of Lab

0.000 to 0.006

Fume Hood Operating Sash Height (inches)

6 to 18

Fume Hood Face Velocity (ft/min)

80 to 99

Predominant Fume Hood Control Type

Variable Volume

Automatic Sash Closers

Hood Face Velocity Setback

Laboratory Occupied Minimum Air Change Rate (ACH)

0.10 to 6.20

Laboratory Unoccupied Minimum Air Change Rate (ACH)

0.10 to 4.10

Source of Lab Minimum Ventilation Rates

Organizational Policy

Building Systems

Clear

Edit

Predominant HVAC System Type

Variable Volume With Reheat

Predominant HVAC Control Type

Direct Digital Control

Exhaust Air Energy Recovery

High-Performance Glycol Run-Around

Predominant Cooling System Type

District Cooling / CHW From Campus Central Plant

Predominant Heating System Type

District Heating / HW Or Steam From Campus Central Plant

Building-level CHP

None

Renewable Energy Generation at Building

None

Geothermal Heat Pump

Heat Recovery Chiller

Low Pressure Drop Design - Air Side

Low Pressure Drop Design - Water Side

True VAV Exhaust (No Bypass Air)

High-Efficiency ULT Freezers

Cascade Air Use

Water-Cooled Lab Equipment

Supply Air Temperature Reset

Static Pressure Reset - Supply Air

Static Pressure Reset - Exhaust Air

Unoccupied Airflow Setback In Labs

Unoccupied Temp Setback In Labs

Pump Head Reset

Exhaust Fan - Wind Speed Response

Chemical Sensing And Airflow Response In Labs

Energy and Operational Emissions Benchmarking

By default, all buildings are shown on the charts. Use the filters to narrow down your peer group.

Scatter Plot



INITIAL DETAILED INPUT

Basic Filters

Clear

Edit

% Lab Area (Net Lab Area / Total Gross Area)

0.00 to 41.00 %

Building Status

Real Building

Type of Record

In Operation

Climate Zones

3A Warm - Humid

Data Type

Data Type

Estimated

Fume Hoods

Clear

Edit

Ducted Fume Hoods per sf of Lab Space

0.0000 to 0.0010

Filtering Fume Hoods per sf of Lab Space

0.000 to 0.000

Linear ft of Fume Hoods per sf of Lab

0.000 to 0.006

Fume Hood Operating Sash Height (inches)

6 to 18

Fume Hood Face Velocity (ft/min)

80 to 99

Predominant Fume Hood Control Type

Variable Volume

Automatic Sash Closers

Hood Face Velocity Setback

Laboratory Occupied Minimum Air Change Rate (ACH)

0.10 to 6.20

Laboratory Unoccupied Minimum Air Change Rate (ACH)

0.10 to 4.10

Source of Lab Minimum Ventilation Rates

Organizational Policy

Building Systems

Clear

Edit

Predominant HVAC System Type

Variable Volume With Reheat

Predominant HVAC Control Type

Direct Digital Control

Exhaust Air Energy Recovery

High-Performance Glycol Run-Around

Predominant Cooling System Type

District Cooling / CHW From Campus Central Plant

Predominant Heating System Type

District Heating / HW Or Steam From Campus Central Plant

Building-level CHP

None

Renewable Energy Generation at Building

None

Geothermal Heat Pump

Heat Recovery Chiller

Low Pressure Drop Design - Air Side

Low Pressure Drop Design - Water Side

True VAV Exhaust (No Bypass Air)

High-Efficiency ULT Freezers

Cascade Air Use

Water-Cooled Lab Equipment

Supply Air Temperature Reset

Static Pressure Reset - Supply Air

Static Pressure Reset - Exhaust Air

Unoccupied Airflow Setback In Labs

Unoccupied Temp Setback In Labs

Pump Head Reset

Exhaust Fan - Wind Speed Response

Chemical Sensing And Airflow Response In Labs

Energy and Operational Emissions Benchmarking

By default, all buildings are shown on the charts. Use the filters to narrow down your peer group.

Scatter Plot

loading

Select Quantities to Plot

Horizontal Axis

Lab Area

Units

%

Vertical Axis *

Site EUI

Units

kBtu/sf/yr

Summary Statistics for Selected Peer Group Buildings

No Matching Buildings

No Matching Buildings

TRB Challenge

I2SL's Laboratory Benchmarking Tool Buildings:

- Met all criteria of TRB: **0**
- BSL3 lab: **2**
- High performance glycol run around: **0**



LABS2ZERO ENERGY SCORE

Alison Farmer, I2SL

This presentation will review the latest demographics of the LBT's database, and will outline some areas where the new data has helped to close gaps that were present when the pilot Energy Score was formulated.

- Attendees will learn about the new, updated scoring formulation, which now includes improved coverage of buildings with significant vivarium space, high fume hood density, and cold climates.
- Speaker will explain which buildings will experience the biggest changes in their Energy Scores due to these updates, and will highlight the building types for which additional data collection is still needed.
- The presentation will include details of the rollout plan for the new Energy Score, and for the new version of the Operational Emissions Score, which uses the same methodology and will be updated at the same time.

“Plans are worthless, but planning is everything.”

- Dwight D. Eisenhower

Plan B...

COMPARABLE UNC BUILDINGS

Building 1

BUILT: 2014

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✓
IMAGING SUITE	✓
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✗

Building 2

COMPREHENSIVE
RENOVATION: 2019

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✗
IMAGING SUITE	✗
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✓

Building 3

BUILT: 2008


PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✗
IMAGING SUITE	✗
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✗

TRANSLATIONAL RESEARCH BUILDING


UNBUILT

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✓
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✓
IMAGING SUITE	✓
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✓


BUILDING USE BY AREA



LOW PRESSURE STEAM




CHILLED WATER




low usage during winter months

ELECTRICITY




Usage consistent across all months

ENERGY CONSUMPTION



ENERGY USE INTENSITY



ENERGY USE INTENSITY TARGET



458 kBtu/sf/yr

Building 1 BUILT: 2015

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✓
IMAGING SUITE	✓
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✗

Building 2 BUILT: 1945 COMPREHENSIVE RENOVATION: 2019

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✗
IMAGING SUITE	✗
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✓

Building 3 BUILT: 2008

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✗
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✗
IMAGING SUITE	✗
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✗


TRANSLATIONAL RESEARCH BUILDING

PROGRAM	
BIOLOGY LAB	✓
CHEMISTRY LAB	✓
BSL3	✓
VIVARIUM	✓
CAGEWASH	✓
CYCLOTRON SUITE	✓
IMAGING SUITE	✓
HVAC	
HIGH-PERFORMANCE GLYCOL RUN-AROUND	✓


*Results in annual estimated energy costs for electric, chilled water, low pressure steam ~ \$1.1 million at 2023-24 rates

ENERGY TARGET

I2SL EUI by Lab Area %




ENERGY USE INTENSITY TARGET



TARGET LABS2ZERO ENERGY SCORE

Target Setter Results

This chart shows the **energy use intensity targets** (Source and Site EUIs) corresponding to your chosen target Pilot Energy Score. The chart is displayed after you click Calculate. Use the Fuel Amounts box below to adjust the fuel mix to match your building.



Target Source EUI: 683 kBtu/ft²
Target Site EUI: 411 kBtu/ft²

Building Information

Please complete all fields.

* Location: Chapel Hill, NC, USA

* Gross Floor Area (sf): 176650

* Lab Type: Bio/Chem Combination

* Predominant Lab Use Type: R&D: Basic Research

* Lab % Area: 41

* Occupied Hours per Week: 168

* Fuel Types Used by Building (check all that apply):
 Electricity
 Natural Gas
 District Steam or Hot Water
 District Chilled Water

* Target Labs2Zero Energy Score: 40

Calculate

Adjust Individual Fuel Amounts

Adjust the breakdown of fuel types to customize your results then click Update Chart. The default is an even split of Site EUI between fuel types. Because different fuel types have different site to source ratios, your target Site EUI may change if you change your fuel mix for a given target score (but your target Source EUI will stay the same).


Electricity 33 % 7,015,851 kWh

District Steam or HW 45 % 32,643 MMBtu

District CHW 22 % 15,959 MMBtu

Update Chart

TARGET LABS2ZERO ENERGY SCORE





Thank YOU!

Amy.Dean@lordaecksargent.com
[Masoom.Haghani@lordaecksargent.com](mailto:Masoome.Haghani@lordaecksargent.com)

Questions?

