

# Cold-Climate Innovation: Sustainable Design at the University at Buffalo



# Introduction

---



**Mo Elsayed**

Senior Building Performance and AI Analyst

Page / Stantec



**Steven Karl**

Principal

Vanderweil Engineers

Mo Elsayed:

As a Senior Building Performance and AI Analyst at Page, Mo works on the integration of emerging technologies into sustainable practices. He specializes in using AI and machine learning to enhance building performance, focusing on energy efficiency, decarbonization, and net-zero strategies.

Steven Karl:

As a Principal at Vanderweil Engineers, Steve's focus is MEP design and his work integrates energy-efficient technologies, waste reduction strategies, and innovative design principles that reduce the carbon footprint and operational costs of laboratory environments and while providing a healthy, productive space for the researchers.

# Learning Objectives

---

## Four learning objectives -

1. Learn how to plan for sustainability from the early stages of the project.
2. Learn how modeling informs the design and impacts system selection.
3. Understand drivers to design a low EUI building in a cold climate.
4. Identify how to implement the ASHRAE hazardous air classification to minimize airflow.

## Project Summary -

The University at Buffalo's new Agrusa Hall for the School of Engineering and Applied Sciences features prototyping, fabrication facilities, collaboration spaces, offices, and labs, aligning with the University's award-winning climate action plan and NY State University Construction Fund sustainability directives.

Laboratories consume five times more energy per square foot than office buildings, a challenge that is amplified in cold climates with significant heating demands. In this technical session, our experts will delve into sustainable design and the strategies employed.

# Buffalo!



# Early Project Intentions

## UB's Climate Action Plan

# UB's 10 in 10

By 2025, UB will directly purchase **100%** of the electricity from **clean energy sources**.

UB will achieve **net zero waste** across all material streams by 2030.

UB will develop **zero carbon commuting** pathways for the campus community.

UB plans to obtain enough **carbon offsets** to fill the gap thus obtaining carbon neutrality by 2030.



Put a price on pollution




Not all electricity is created equal



Electrify our ride



Keep it cozy and green



Waste not



Flip the switch



Commute responsibly



Taking stock of our food system




Investing locally to provide flexibility




Making it happen

# Early Project Intentions: LEED Priorities



# Early Project Intentions: Define Net-Zero



**Net-Zero Carbon**

**Net-Zero Energy**

● **Reduce Emissions**  
Electrify & minimize energy needed

● **Onsite Renewables**  
Offset any energy needed with onsite renewables

● **Carbon Offsets**  
Offset any power used with purchased carbon offsets

CO2 emissions

## Early Project Intentions: Target EUIs

---

**EUI** Program Directive 1B-2 – Net-Zero Carbon New Buildings and Deep Energy Retrofits (suny.edu)

### Net Zero Carbon Building Site EUI Targets

Building/Space Type	EUI
Theater, Performing Arts, Sports Arena	22
Gymnasium, Field House, Fitness Center, Multipurpose/assembly space, Student Activities Center, Broadcasting Studio	26
Ice Rink, Pool	130
Office	29
Classroom	30
Residence Hall	35
Clinic/Outpatient Facility	41
Preschool/daycare	44
Public Safety/ Campus PD, Library	58
Coffee Shop, Cafe	79
Hospital/Inpatient Health	113
Lab: Physics/Geology	128
Kitchen with dining area	144
Lab: Bio/Chem (wet)	160

# Early Project Intentions: Target EUIs






# SITE



Lake  
La Salle

# SITE



WHITE ROAD

WHITE ROAD

Ketter Hall

Davis Hall

Jarvas Hall

Furnas Hall

MARY TALBERT WAY

MARY TALBERT WAY

Bonner Hall

Bell Hall

Student Union

**Agrus  
a Hall  
Site**

**EMERGENCY FIRE LANE**

**LEE ROAD RIGHT OF WAY**


**FUTURE LIGHTRAIL PLATFORM**

University Bookstore

UB Commons

Lake  
La Salle

# SITE



WHITE ROAD

WHITE ROAD

Ketter Hall

Davis Hall

Jarvas Hall

Furnas Hall

MARY TALBERT WAY

MARY TALBERT WAY

Bonner Hall

Bell Hall

Student Union

Agrus  
a Hall  
Site

EMERGENCY  
FIRE LANE

LEE ROAD  
RIGHT OF WAY





FUTURE  
LIGHTRAIL  
PLATFORM

University Bookstore


UB Commons

Lake  
La Salle

# Early Optimization: Passive Solar Harness



Maximize solar harness in Winter conditions




Bar Scheme | Fully exposed South façade  
for optimal BIPV harness and daylight  
Tilted South façade | 10% added Solar exposure

# Early Optimization: Site Analysis



# SITE



WHITE ROAD

WHITE ROAD

LEE ROAD

LEE ROAD

Ketter Hall

Davis Hall

Jarvas Hall

Russell L. Agrusa Hall

Furnas Hall

MARY TALBERT WAY

MARY TALBERT WAY

Bonner Hall

Bell Hall

Student Union

University Bookstore

Lake La Salle

UB Commons

# Level 1 + 2 Building Blocks


---




Common Assembly Spaces + Workshops  
*"Big Blue"*



Core / Building Services  
*(elev, restrooms, loading, etc.)*



Atrium + Event Space




Major Circulation  
*(including connection to Jarvis)*




Stairs

# 'Big Blue'

Project assembly space for students





- Research Labs Teaching Labs
- Circulation Stairs
- Collaboration Building Support



# 'Big Blue'

Project assembly space for students




- Research
- Labs
- Teaching Labs
- Circulation
- Stairs
- Collaboration
- Building Support




# 'Big Blue' – Level 1

Project assembly space for students




- Research Labs Teaching Labs
- Circulation
- Collaboration
- Stairs
- Building Support




# Balancing Exposed vs. Enclosed

## Split Core




- Research Labs Teaching Labs
- Circulation
- Stairs / Elevators
- Collaboration
- Building Support





# Balancing Exposed vs. Enclosed

Flexible Student Success Atrium



- Research Labs Teaching Labs
- Circulation
- Stairs
- Collaboration
- Building Support







**Driving movement and promoting visibility through the heart of the building**





# Site Solar Radiation

15% increased solar gain through optimized façade angle




# Wind Analysis



# Enclosure Design

Homage to Marcel Breuer




## OPEN V. CLOSED

Furnas Hall, University at Buffalo  
1978




## GROUNDING V. PROJECTED

Whitney Museum of American Art,  
Manhattan 1966



## PARALLEL V. PERPENDICULAR



NYU Technology II, Bronx 1956




## GLAZED V. OPEN

UNESCO Headquarters, Paris 1958

# Early Optimization: Window to Wall Ratio Per Facade




# Early Optimization: Window to Wall Ratio Per Facade



IGU (ASHRAE baseline Standard; U-value 0.45; SHGC 0.36): EUI = 75; 2,467,913 kWh annually  
Triple LoE Film (77) Clr 3mm/6mm Air; U 0.33; SHGC 0.45: EUI = 72; 2,359,436 kWh annually [4% Reduction]  
Triple Glazing Window; U 0.11; SHGC 0.38: EUI = 67; 2,209,277 kWh annually [10.6% Reduction]

# Design Optimization: Shading



	Daylit [%]	Energy/ Area	Glare [%]
	<b>sDA</b>	<b>Energy</b>	<b>GA</b>
BASELINE	65.33	55.97	0.23
Current	57.33	55.78	0.17
<b>Vertical Left Shades</b>			
Shade_0.5_1_0_-45	66.67	56.03	0.21
Shade_1_1_0_-45	66	56.12	0.22
Shade_1.5_1_0_-45	65.33	56.16	0.23
Shade_2_1_0_-45	66	56.16	0.22
Shade_0.5_1_0_-30	66	55.95	0.22
Shade_1_1_0_-30	65.33	55.93	0.22
Shade_1.5_1_0_-30	65.33	55.91	0.21
Shade_2_1_0_-30	64.67	55.86	0.21
Shade_0.5_1_0_-15	65.33	55.85	0.22
Shade_1_1_0_-15	64	55.77	0.22
Shade_1.5_1_0_-15	64.67	55.66	0.21
Shade_2_1_0_-15	64.67	55.62	0.19
Shade_0.5_1_0_0	64	55.77	0.21
Shade_1_1_0_0	64	55.62	0.21
Shade_1.5_1_0_0	62.67	55.51	0.19
Shade_2_1_0_0	62	55.42	0.18
Shade_0.5_1_0_15	64	55.78	0.21
Shade_1_1_0_15	63.33	55.57	0.19
Shade_1.5_1_0_15	61.33	55.47	0.18
Shade_2_1_0_15	58.67	55.49	0.17


## Design Optimization: Shading, Balancing Daylight and Energy



# Design Optimization: Shading, Balancing Daylight and Energy




# Design Optimization: Energy Model for Design Decisions




## Model Assumptions:

- 5 zones per floor
- Proportionally mixed program type
- Reduced LPDs with daylight light sensors
- Envelope R values, WWR, and shading as set by design team
- Basic ASHRAE HVAC templates on auto sized with 11-degree delta






## Simulated Energy Consumption



# Design Optimization: Energy Model for Optimization Permutations





# Path to Net Zero



# Path to Net Zero



Additional Solar PV area, offsite Solar PV, or further energy reduction required to meet net zero energy.






AGRUSA HALL  
SCHOOL OF BUSINESS

# Parametric Model Export



## COMPARITIVE ANALYSIS FOR: (500-ton cooling load defined)

- a. BASE BUILDING ASHRAE Packaged VAV with PFP Boxes: **EUI = 77.5**
- b. Bldg with Fan coils, chiller, and electric resistance boiler: **EUI = 47.4**
- c. Bldg with VAV chiller with central air source heat pump: **EUI = 45.3**
- d. Bldg with Water Source heat Pumps with GSHP **EUI = 34.98**




# ASHRAE HAZARD CLASSIFICATION

# Reduce & Right-Size Demand

- Reduce demand for outdoor air
- Reuse indoor air
- Reduce need to condition outdoor air
- Reduce mechanical equipment loads
- Safety is the priority!



# Classification of Air (ASHRAE 62.1)




ASHRAE 62.1-2022 Air Classifications

\*Recirc only within the same space

# ASHRAE Hazard Classification

Risk factor	Examples
0 (Negligible)	<ul style="list-style-type: none"> <li>• Computer and instrumentation laboratories</li> <li>• Secondary school teaching laboratories</li> <li>• Warm rooms/cold rooms</li> </ul>
1 (Low)	<ul style="list-style-type: none"> <li>• Secondary school teaching laboratories</li> <li>• Shop areas with point sources of hazardous chemicals</li> <li>• Quality control laboratories</li> <li>• Biology laboratories with no volatile hazards beyond disinfectants</li> </ul>
2 (Moderate)	<ul style="list-style-type: none"> <li>• Upper-level undergraduate research laboratories</li> <li>• Biochemistry laboratories focused on aqueous solutions</li> <li>• Academic teaching laboratories</li> </ul>
3 (High)	<ul style="list-style-type: none"> <li>• Inorganic/organic synthesis laboratories</li> <li>• Typical research laboratories</li> </ul>
4 (Very high)	<ul style="list-style-type: none"> <li>• Chemical development laboratories</li> <li>• Polymer synthesis laboratories</li> <li>• Organic/inorganic chemical synthesis laboratories</li> <li>• Special high-hazard research laboratories</li> </ul>

(Source: [ASHRAE](#))



*ASHRAE Classification of Laboratory Ventilation Design Levels*

# ASHRAE Hazard Classification

## Classification of Laboratory Ventilation Design Levels

Table 3 LVDL Requirements for Design and Operation (continued)

ID	Criterion Description	LVDL-0 Requirement	LVDL-1 Requirement	LVDL-2 Requirement	LVDL-3 Requirement	LVDL-4 Requirement
Supply and Exhaust Airflow Requirements						
4	Occupied minimum exhaust ventilation rate  (See the text for the application of minimum ventilation rates, which should not be determined without the supporting risk analysis under any condition.)	Standard 62.1	Standard 62.1	4-6 air changes based on sufficient information for hazard review by an EH&S professional and completion of review.  General ventilation rate may be lower if validation of effectiveness of ventilation suggests sufficient dilution and contaminant removal.	If all emission sources of concern are contained by use of local exhaust ventilation, and if inadequate air distribution or mixing from the general ventilation system is not a concern: • Typically 6 ach*, otherwise: • Increase air changes per hour (8 or more*) or investigate and improve ventilation effectiveness.  General ventilation rate may be lower if validation of effectiveness of ventilation suggests sufficient dilution and contaminant removal.	If all emission sources of concern are contained by use of local exhaust ventilation, and if inadequate air distribution or mixing from the general ventilation system is not a concern: • Typically 8 ach*, otherwise: • Increase ACH (10 or more*) or investigate and improve ventilation effectiveness.  General ventilation rate may be lower if validation of effectiveness of ventilation suggests sufficient dilution and contaminant removal.
		LVDL-0 PROJECT CRITERIA VENTILATE PER ASHRAE 62.1 NO EXH REQ'D RECIRCULATION ACCEPTABLE	LVDL-0.5 PROJECT CRITERIA VENTILATE PER ASHRAE 62.1 - SIMILAR TO COPY/PRINT ROOM (0.5 CFM / FT2) FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE	LVDL-1 PROJECT CRITERIA RELAX SUCF DIRECT 23-1 CRITERIA TO 4 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE	LVDL-2 PROJECT CRITERIA SUCF DIRECT 23-1 CRITERIA TO 6 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE	LVDL-3 PROJECT CRITERIA SUCF DIRECT 23-1 CRITERIA TO 8 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE


\* Scale minimum air change rates upward based on project-specific analysis. Technologies such as indoor air quality sensing can be used to support the results of this analysis.

HAZARD LEVEL	PROJECT CRITERIA
LVDL-0	VENTILATE PER ASHRAE 62.1 NO EXHAUST REQUIRED RECIRCULATION ACCEPTABLE
LVDL-0.5	VENTILATE PER ASHRAE 62.1 - SIMILAR TO COPY/PRINT ROOM 0.5 CFM / FT2 FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE
LVDL-1	RELAX SUCF DIRECT 23-1 CRITERIA TO 4 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE
LVDL-2	SUCF DIRECT 23-1 CRITERIA TO 6 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE
LVDL-3	6 AIR CHANGES FULLY EXHAUSTED NO RECIRCULATION AT AHU LOCAL FCU RECIRCULATION WITHIN SAME SPACE IS ACCEPTABLE

\*ROOMS WITH NO DIRECT LAB FUNCTION BUT SEE SOME ACTIVITY FROM TIME TO TIME

# Working Session to Classify Spaces

## Computer Science 6,300 NSF




## Research & Innovation Hub 7,800 NSF




# Working Session to Classify Spaces


## Instructional Spaces 8,000 NSF




## Shared 9,675 NSF



## Service 2,500 NSF



## Student Headquarters 14,700 NSF



# Final Program

Space ID	Space Name and Type	Number of People	Number of Spaces	NASF Per Space	NASF Total
<b>0.0</b>	<b>Events &amp; Public Spaces</b>				
	Sub-total Events & Public Spaces		15		9,675
<b>1.0</b>	<b>Research &amp; Innovation Hub</b>				
	Sub-total Research & Innovation Hub		11		7,800
<b>2.0</b>	<b>Student Headquarters</b>				
	Sub-total Student Headquarters		21		14,700
<b>3.0</b>	<b>Instructional Spaces</b>				
	Sub-total Instructional Spaces		14		14,300
<b>4.0</b>	<b>Student Excellence &amp; Support</b>				
	Sub-total Student Excellence & Support		136		16,560
	<b>Building Support</b>				
<b>5.0</b>					
	Sub-total Building Support		18		2,800
			<b>TOTAL BUILDING NASF</b>		<b>65,835</b>
			net to gross multiplier		1.70
			<b>TOTAL BUILDING GSF</b>		<b>111,920</b>


RISK 1 TOTAL SF = 15,750

RISK 2 TOTAL SF = 2,400

RISK 3 TOTAL SF = 600

ALL OTHER SPACES RISK 0

# Room Schematics



# AHU Riser Diagram

HAZARDOUS EXHAUST


LAB SUPPLY

OFFICE SUPPLY

OFFICE RETURN

LAB RETURN

GENERAL EXHAUST AIR



# AHU Schematics

HAZARDOUS EXHAUST



LAB SUPPLY

OFFICE SUPPLY

OFFICE RETURN

LAB RETURN

GENERAL EXHAUST AIR



# HVAC Penthouse

HAZARDOUS EXHAUST



LAB SUPPLY

OFFICE SUPPLY

OFFICE RETURN

LAB RETURN



GENERAL EXHAUST



# Risk Level 0 Example



---

Typical Computer Lab (30 seats) – 900 NSF





# Risk Level 1 Example

Common Project Assembly  
3,000 SF  
"Clean"





# Risk Level 1 Example

Common Project Assembly  
3,000 SF  
“Dirty”



# Risk Level 3 Example

Common Fume Hood Bay – 600 SF



## Reductions

---

**PRELIMINARY SUPPLY AIRFLOW = 75,000 CFM**

**PRELIMINARY TONNAGE = 450 TONS**

**PRELIMINARY HAZARD EXHAUST = 17,000 CFM**

## Reductions

---

PRELIMINARY SUPPLY AIRFLOW = 75,000 CFM

**FINAL SUPPLY AIRFLOW = 63,000 CFM**

PRELIMINARY TONNAGE = 450 TONS

**FINAL TONNAGE = 360 TONS**

PRELIMINARY HAZARD EXHAUST = 17,000 CFM

**FINAL HAZARDOUS EXHAUST = 15,000 CFM**

# HEAT PUMP SYSTEM DESIGN

# SUNY & State Policies

---

- **New York State Executive Order 22**

To the fullest extent feasible, beginning January 1, 2024, all new construction submitted for permitting by Affected Entities shall avoid infrastructure, building systems or equipment that can be used for the combustion of fossil fuels, excluding necessary use for backup emergency generation and process loads, provided that Affected Entities shall avoid the use backup emergency diesel generators where practicable.

Executive Order  
SEPTEMBER 20, 2022

**No. 22: Leading by Example: Directing State Agencies to Adopt a Sustainability and Decarbonization Program**

	<b>Directive: 1B-2 CLCPA, E.O. 22 and SUNY Policy Compliance</b>
	Responsible Office: Design & Construction
	Last Revised Date: July 2023



## Heating Options – Decisions to be made

---





Replacement of heating equipment with **ELECTRIC RESISTANCE HEATING**




Replacement of heating equipment with **HEAT PUMPS** connected to various thermal energy sources.



# Thermal Electrification Comparison



# Institutional Carbon Goals



## Buildings Carbon/Cost

As a large part of UB's total emissions, quantifying each building's emissions is a vital step in UB's path to neutrality. This page dynamically shows the emissions for each building across all three campuses.

### Navigation tips:

1. Choose to compare by MTeCO2 or cost
2. Filter as desired, hold CTRL for multiple selections
3. Right-click the bar chart and see "next level" data or "drill down" to monthly data
4. Hover over buildings in the map for energy benchmark
5. View trend analysis page for alternate visual representation and analysis of the same data

Compare by MTeCO2 | Compare by cost

**Campus**

Downtown  
 North Campus  
 South Campus

**Year**

Select all  
 2011  
 2012  
 2013  
 2014  
 2015


**Building**

Select all  
 Alumni Arena  
 Band Hall  
 Early Hall  
 Beane Service Center  
 Bell Hall

**Building Type**

Class  
 Lab  
 Multifamily Housing  
 N/A  
 Office

Navigation icons: ⏪ ⏩ ⏴ ⏵



<https://www.buffalo.edu/climate-action/how.html>

# University at Buffalo South Campus – Energy Master Plan




Figure B-2: UB S. Campus path to carbon neutrality

## Heating Options – Direction!

---

Replacement of heating equipment with **ELECTRIC RESISTANCE HEATING**



Replacement of heating equipment with **HEAT PUMPS** connected to various thermal energy sources.

# Plant Options

---

The following systems were considered for the heating and cooling generation at the Central Utility Plant (CUP)

## HEATING SYSTEMS

Heat-shift chillers

Air-source heat pumps

Ground Source heat pump – Geothermal

**Campus Steam**

Natural Gas Boilers

Electrical Boilers

## COOLING SYSTEMS

Heat-shift chillers

Air-source heat pumps

Ground Source heat pump – Geothermal

Water Cooled Chillers

Air Cooled Chillers

**Campus Chilled Water**

# Plant Options

---

The following systems were considered for the heating and cooling generation at the Central Utility Plant (CUP)

## HEATING SYSTEMS

Heat-shift chillers

Air-source heat pumps

Ground Source heat pump – Geothermal

Campus Steam

Natural Gas Boilers

Electrical Boilers

## COOLING SYSTEMS

Heat-shift chillers

Air-source heat pumps

Ground Source heat pump – Geothermal

Water Cooled Chillers


Air Cooled Chillers

Campus Chilled Water


## BIG IDEAS!

**Campus Chilled Water -> Water Source Heat Pump = Building Heating Water!**

# Heat Pumps - Heating




# Heat Pumps - Cooling



# Building Profiles

## HVAC Load Profiles

Monthly Load Profiles - view table





# Meetings with Owner

		Avg Sup Temp	Avg Ret Temp	Avg Flow	Total Tonnage	Avg OAT
		Deg F	Deg F	GPM	Tons	Deg F
JAN	AVG	61.0	60.7	5168.6	0.0	34.1
JAN	MAX	63.9	63.4	5880.6	0.0	48.6
JAN	MIN	58.6	58.3	5109.8	0.0	17.0
FEB	AVG	61.1	60.9	5976.1	1.8	33.6
FEB	MAX	64.4	64.0	7243.9	71.5	61.0
FEB	MIN	57.7	57.7	5581.6	0.0	3.0
MAR	AVG	61.2	60.8	9209.0	0.0	37.0
MAR	MAX	64.2	63.9	14725.5	0.0	58.5
MAR	MIN	60.0	59.6	5920.9	0.0	22.4
APR	AVG	58.5	59.5	10952.4	648.7	50.7
APR	MAX	67.5	67.0	17446.9	5331.4	86.3
APR	MIN	40.7	45.4	8497.7	0.0	26.6
MAY	AVG	49.1	52.0	11734.2	1598.8	60.1
MAY	MAX	63.8	63.4	15355.6	5368.6	95.5
MAY	MIN	39.4	45.1	4714.4	0.0	35.8
JUN	AVG	44.6	50.0	13413.1	3101.2	69.3
JUN	MAX	56.5	57.0	17068.6	6818.6	100.2
JUN	MIN	40.2	46.4	10456.0	0.0	51.4
JUL	AVG	42.3	49.7	13950.6	4396.1	75.2
JUL	MAX	49.8	53.7	16590.2	8209.5	96.2
JUL	MIN	40.1	46.2	11359.9	1061.0	59.8
AUG	AVG	43.3	49.5	13921.7	3644.4	70.7
AUG	MAX	48.4	52.9	16585.6	7077.5	84.8
AUG	MIN	40.1	45.6	11358.3	1098.4	53.0
SEP	AVG	44.4	49.6	13722.7	2959.6	66.3
SEP	MAX	57.5	58.0	17709.0	8064.6	92.2
SEP	MIN	40.2	45.9	10292.7	0.0	47.4
OCT	AVG	51.6	54.3	11811.3	1495.5	56.8
OCT	MAX	64.0	63.7	16347.5	5997.1	86.5
OCT	MIN	40.3	45.7	4710.4	0.0	33.9
NOV	AVG	59.8	59.9	11402.1	164.4	41.7
NOV	MAX	65.0	64.9	16578.7	2571.8	62.1
NOV	MIN	45.4	48.1	9898.7	0.0	24.3
DEC	AVG	62.6	62.4	11196.9	0.0	40.6
DEC	MAX	67.8	67.5	15303.5	0.0	62.6
DEC	MIN	58.8	58.8	9731.9	0.0	25.3


Jan = 61F Average

July = 49F Average

August = 40F Minimum


Dec = 68F Max

# Existing Campus Arrangement



# Heat Pump System


- Leverage existing campus infrastructure
- Connect to systems to reduce carbon fuel at Plant



# Heat Pump System – Winter Operations

- Utilize Campus Chilled Water in winter for heating (reserve connection to CHW)

- Small Variations = Big Results!



# OUTPUTS

---

% Projected Energy Cost Savings ~32- 39 %


Final Equipment Selections Heat COP

Cooling COP = 3.44


Heating COP = 4.44

Combined = 7.88

# Resiliency & Redundancy



# Benefit – Molecular Design



# Benefits – Reduced Electrical Generator Sizing

---

## Gas-fired heating:



400 kW

## All-electric:




1 MW

---

# Benefits – Limited Roof Top Equipment

---



# QUESTIONS?

