



AIM for Success with Advanced Exhaust System Controls



Brad C. Cochran, P.E.
Sr. Principal
CPP Wind Engineering

I2SL 2025 Annual Conference
Dallas, TX | October 21, 2025

LEARNING OBJECTIVES:

- Get a brief introduction into the I2SL Labs2Zero AIM Report
- Understand how different AIM measure may impact your EUI and Energy Score
- How to take the results of the AIM report and develop a business case for implementing VAV lab exhaust control
- Learn the process involved in designing and implementing VAV lab exhaust control

Labs2Zero



- An Energy and Carbon Emission Score Card for Lab Buildings that encompass both operational and embodied emissions, as well as a way to set targets for new lab building scores
- An Actionable Insights and Measures (AIM) Report that suggests ways to improve a lab's Energy and Emissions Scores
- A Design2Zero Tool which suggests ways to achieve energy and emissions goals in new lab construction (*Future*)
- A Certification Program to independently verify lab energy and emissions performance (*Future*)
- Training and Accreditation to support the certification program (*Future*)

AIM Report

AIM is an automated energy audit for lab buildings!

AIM imports your building data from lbt.i2sl.org




You build a package of measures that is customized to your facility

AIM calculates savings and costs

Takes interactive effects into account, shows next steps, stakeholders to involve

Relevant case studies



PDF AIM Report to share



Example – CPP Wind Engineering Laboratory



Labs2Zero Scorecard



AIM Report

Building Information

Predominant Lab Use
Other



Predominant Lab Type
Testing / Quality Control



Organization Type
Commercial: Other



Percentage Lab Area
53%



Building Gross Area
38,000 ft²



Ducted Fume Hoods
20



Building Performance (2024)

Energy Score
78

Site EUI
153.1 kBtu/ft²

Annual Energy Cost
\$245,503

Add Measure

- Enhanced Exhaust Fan System Controls**
ECM045
 Annual Energy Savings: \$19,141 | Incremental Cost: \$130,600 | Simple Payback: 6.8 years | Energy Score: 82 ↑4 | Site EUI: 143.5 kBtu/ft² ↓9.5
- Exhaust Duct Static Pressure Setpoint Reset**
ECM204
 Annual Energy Savings: \$8,712 | Incremental Cost: \$3,704 | Simple Payback: 0.4 years | Energy Score: 80 ↑2 | Site EUI: 148.7 kBtu/ft² ↓4.3
- Supply Duct Static Pressure Setpoint Reset**
ECM203
 Annual Energy Savings: \$7,682 | Incremental Cost: \$3,704 | Simple Payback: 0.5 years | Energy Score: 79 ↑1 | Site EUI: 150.4 kBtu/ft² ↓2.7
- Frequent Filter Replacement for Air Handlers**
ECM059A
 Annual Energy Savings: \$5,489 | Incremental Cost: \$3,795 | Simple Payback: 0.7 years | Energy Score: 79 ↑1 | Site EUI: 151.2 kBtu/ft² ↓1.9
- Low Pressure-Drop Filters for Air Handlers**
ECM059B
 Annual Energy Savings: \$5,489 | Incremental Cost: \$14,266 | Simple Payback: 2.6 years | Energy Score: 79 ↑1 | Site EUI: 151.2 kBtu/ft² ↓1.9

AIM Report



Enhanced Exhaust Fan System Controls

ECM045

Add Measure to Package

Already in Building

Financial information

Annual Energy Savings

• **\$19,141**

Package

\$19,141

Incremental Cost

• **\$130,600**

Package

\$130,600

Simple Payback

• **6.8 years**

Package

6.8 years

Energy Impacts

Energy Score

82 ↑ 4

Current Package: 78

Site EUI

143.5 kBtu/ft² ↓ 9.5

Current Package: 153.1kBtu/ft²

Description

This measure involves enhancing the building's exhaust fan systems in order to reduce the amount of energy consumed without adversely impacting downwind exposure levels to lab exhaust emissions.

Many lab exhaust systems operate in a constant air volume (CAV) mode to maintain a prescriptive exit velocity. This prescribed exit velocity is either defined using rule of thumb values (typically 3000 fpm / 15.2 m/s) or through dispersion modeling. If dispersion modeling is used, the exit velocity is defined by assuming the worst-case emission scenario and the worst-case wind conditions that result in the highest concentration at a location of concern.

With these CAV systems, if the ventilation exhaust demand within the laboratory is reduced, for example through the use of variable airflow controls, then bypass air, which is outside air bled into the exhaust ductwork just prior to the fans, is used to make up the difference between the total airflow exhausted out of the building and the total airflow (out of the stack) that is needed to maintain the prescribed exit velocity. This can result in an exhaust system that operates under full load conditions continuously and that may be responsible for perhaps 30% of the entire electrical power consumption of the building. Note that some CAV exhaust systems use staged fan controls, where each fan on a given exhaust plenum operates at constant speed but individual fans are de-energized when conditions permit; this control method results in some energy savings versus the fully CAV approach.

With enhanced controls, the exhaust fan systems can be converted to variable air volume (VAV) control, which reduces or even eliminates the need for bypass air. Enhanced controls can potentially save significant energy while also maintaining acceptable exposure levels downwind of the exhaust stack.

AIM Report

CPP Windsor ...

Generate Report

- Impacts & Measures
- Savings Details
- Case Studies
- Reports

Financial Impacts

Annual Energy Savings \$78,857	Implementation Cost \$190,214	Simple Payback 2.4 years
--	---	------------------------------------

Energy Impacts


Energy Score 95 ↑ 17 Existing building: 78	Site EUI 87.8 kBtu/ft ² ↓ 65.3 Existing building: 153.1 kBtu/ft ²
---	--

Measures Included in Package (3 Measures) [Remove all](#)

Only the measure at the top of the package can be removed. Add Measure +

3	Risk-Based Airflow Optimization ECM083	Annual Energy Savings ● \$53,131	Incremental Cost ● \$57,800	Simple Payback ● 1.1 years	Energy Score 95 ↑ 11	Site EUI 87.8 kBtu/ft ² ↓ 52.5	
2	Exhaust Duct Static Pressure Setpoint Reset ECM204	Annual Energy Savings ● \$6,585	Incremental Cost ● \$1,814	Simple Payback ● 0.3 years	Energy Score 84 ↑ 2	Site EUI 140.3 kBtu/ft ² ↓ 3.3	
1	Enhanced Exhaust Fan System Controls ECM045	Annual Energy Savings ● \$19,141	Incremental Cost ● \$130,600	Simple Payback ● 6.8 years	Energy Score 82 ↑ 4	Site EUI 143.5 kBtu/ft ² ↓ 9.5	

AIM Report



CPP Windsor

CPP Windsor

7365 Greendale Road, Windsor, CO, USA

Genentech Labs Save Energy, Operating Costs in Exhaust Systems by Converting to VAV

 Match Score

60.8

Genentech implemented a site laboratory energy optimization program implemented in 2010 at their South San Francisco campus. The project aimed to reduce energy consumption in 24 laboratory exhaust systems across 16 research lab buildings on the south, central, and north campuses by converting constant volume manifolded laboratory exhaust fans to VAV control. CPP Wind Engineering Consultants conducted extensive plume dispersion modeling for each exhaust system in order to implement a wind-responsive laboratory exhaust control system.

CPP designed and constructed three separate 1:240 scale models of the campus and placed them in their Atmospheric Boundary Layer Wind Tunnels. Tracer gases were released from each exhaust stack, and downwind concentration measurements were obtained at various critical locations under a full range of wind directions and simulated wind speeds. Based on the modeling results, a wind-responsive control system was implemented, where an anemometer was installed on each of the three campuses. The building automation system (BAS) read average wind speeds and directions, and a look-up table defined the minimum allowable volume flow rate for the current wind conditions. A new sequence of operation was developed to control fan speeds to meet duct static setpoints, ensuring fans operated at or above the minimum allowable flow rate based on wind conditions.

After implementing the wind-responsive systems, one month of trend data was collected to verify system performance. Energy consumption data were trended and compared to pre-implementation measurements. Results indicated over \$1.2 million per year in energy savings across the Genentech campus. Total energy savings amounted to 9,428,210 kWh/year, reducing annual energy consumption from 17,586,252 kWh/year to 8,158,042 kWh/year. The total annual cost savings were over \$1.2 million, with the annual cost decreasing from \$2.3 million to \$1.1 million. The payback period, after rebates, was less than one year. Detailed energy consumption and cost savings for individual buildings and exhaust systems show the specific reductions achieved at each location.

This project emphasizes the effectiveness of wind-responsive control systems for laboratory exhaust, highlighting significant energy and cost savings. A key lesson learned is that detailed plume dispersion modeling is crucial for determining minimum flow rates and ensuring compliance with air quality standards. The successful implementation was verified with extensive data collection and monitoring. The use of scale models in wind tunnels allowed for accurate prediction of exhaust plume behavior under various wind conditions, which was important for designing an effective wind-responsive control strategy.

List of Measures Used in this Case Study:

1. Enhanced Exhaust Fan System Controls (ECM045)

Executive Summary

Laboratory facilities often present significant opportunities for energy savings and emissions reductions. This report reveals the potential energy cost savings and implementation costs of a package of energy-saving measures applicable to CPP Windsor

Annual Energy Cost Savings

\$78,857

Package Implementation Cost


\$190,214

Simple Payback

2.4 years

Building Performance (2024 data)

	Existing Building		Building With Package
Annual Energy Cost	\$245,503	→	\$166,645
Labs2Zero Energy Score	78	→	95
Site EUI	153.1 kBtu/ft ²	→	87.8 kBtu/ft ²



Next Steps – Site Specific Feasibility Assessment

Defining Opportunities – Advanced Exhaust System Controls

Gather Exhaust System Information

- Fan make
- Fan model
- RPM
- Volume flow rate
- VFDs installed
- Bypass dampers

Chemistry Research Building										
Total Lab Exhaust Flow (cfm): 126,000 Lab Equipped with Building Automation System? <input type="checkbox"/> Hourly Load Profiles Available? <input type="checkbox"/> Drawings indicating how the fans are manifolded available? Yes										
Fan Name	Exhaust Volume Flow (cfm) ¹	Exhaust Velocity (fpm) ¹	Fan Make/ Model	Fan Curve Available?	Static Pressure (In WG)	By-pass on Manifold ?	By-pass cfm or louver position	Sequence of Operation (i.e., CV w/ N+1 Redundancy, Staged CV, or VAV)	VFDs?	Stack Height Above Local Roof (ft)
EAHU-1a,b	31,500	2,766			3 to 7.5	Yes			Yes	7.4
EAHU-2a,b	31,500	2,766			3 to 7.5	Yes			Yes	7.4




¹ Per "as-built" documents

Next Steps – Site Specific Feasibility Assessment

Defining Opportunities – Advanced Exhaust System Controls

Collect Trend Data

- Fan status
- Fan speed (with VFD)
- Duct static pressure
- Bypass damper position and/or AHU cfm





Next Steps – Site Specific Feasibility Assessment

Defining Opportunities – Advanced Exhaust System Controls

Baseline

Mode of Operation: Constant Volume 4 of 5 Fans Operating at Full Load

Fan	Make	Model	Hp	Volume Flow Rate (cfm)	Annual Energy Consumption (kW-hr/year)	Annual Energy Consumption (\$)
EF-1	ACME	48-CEN	32.0	25,000	209,119	31,368
EF-2	ACME	48-CEN	32.0	25,000	209,119	31,368
EF-3	ACME	48-CEN	32.0	25,000	209,119	31,368
EF-4	ACME	48-CEN	32.0	25,000	209,119	31,368
EF-5	ACME	48-CEN	32.0	Stand-By		




ENERGY REDUCTION SUMMARY

Annual	Annual	Annual	Annual	Annual	Annual
kW-hr/year	(\$)	(\$)	(\$)	(\$)	(\$)
509,497	76,424	1.09	82.1%	\$484,189	1162%

Next Steps – Fan Energy Optimization Assessment

- ✓ Conduct a Dispersion Modeling Study to Define Minimum Acceptable Volume Flow Rates/Exit Velocities
- ✓ Perform Pre-Functional Testing to Identify Exactly How the Systems are Currently Operating and Define any Critical Operational Deficiencies
- ✓ Update the Sequence of Operation for VAV Control
- ✓ Implement the Updated Control Code
- ✓ Commission VAV Control System
- ✓ **SAVE ENERGY – REDUCE CARBON EMISSIONS**
 - Reduce External Noise Generation
 - Extend the Life of the Equipment
 - Maintain Better Static Pressure Control



SUMMARY:

- The I2SL Labs2Zero AIM Report is a great tool to identify possible energy savings/carbon reduction measures for your laboratory facility
- Energy Savings Predictions are fairly generic and your results may vary
- If a measure, such as the Advanced Exhaust System Control appears viable, then a site specific feasibility assessment should be conducted to build a business case.
- If the business case looks good. Then carry out a fan energy optimization assessment.

QUESTIONS?

For More Information

Brad Cochran, P.E.
Sr. Principal
bcochran@cppwind.com

CPP, Inc.
7365 Greendale Road
Windsor, CO 80550

(970) 221-3371

CPP